

Addendum #1 “2025-HUGHES EST”

ELEVATED STORAGE TANK EXTERIOR COATING REPAIR AND HOLES IN ROOF PLATES

The following changes:

Bid due date changed to 4pm Wednesday July 2nd 2025,

RFP is for external sandblasting/ coating only

Sand blasting required at SSPC-SP No. 10 (95% free of visible contaminants) levels

Coatings shall be a 3 coat high build zinc epoxy polyurethane system meeting the AWWA D102 and TCEQ standards (minimum 7mils DFT)

Primer Tnemec series 90-97 Tnemec zinc or equivalent

Intermediate coat: Tnemec series N69 Epoxyline II or equivalent

Finish Coat: Tnemec series 1074 (U)Endura shield or equivalent

Final acceptance of coating will be conducted the City or designee

No logo is required for this project